


NON-INSULATED TERMINAL LUGS Y-TYPE



pe	Dwire Range		ϕD	$\phi d1$	E	No. US-made bolt screws		B	$\phi d2$	L	Maximum current	
	CM	mm ²					F				A	
SNB1.25-3						#4		6.5	5.7	3.2	16	
SNB1.25-3.5S						#6		6.5	5.7	3.7	16	
SNB1.25-3.5L						#6		6.5	6.4	3.7	16	
SNB1.25-4S						#8		6.5	6.4	4.3	16	
SNB1.25-4M						#8		6.5	7.2	4.3	16	
SNB1.25-4L						#8		6.5	8.1	4.3	16	
SNB1.25-5S						#10		6.5	8.1	5.3	16	
SNB1.25-5L						#10		6.5	9.5	5.3	16	
SNB1.25-6S						4-Jan		6.5	9.5	6.5	16	
SNB1.25-6L	22-16	0.5~1.5	3.4	1.7	4.8	4-Jan		11	12	6.5	22	19
SNB2-3						#4		6.5	5.7	3.2	16	
SNB2-3.5S						#6		6.5	5.7	3.7	16	
SNB2-3.5L						#6		6.5	6.4	3.7	16	
SNB2-4S						#8		6.5	6.4	4.3	16	
SNB2-4M						#8		6.5	7.2	4.3	16	
SNB2-4L						#8		6.5	8.1	4.3	16	
SNB2-5S						#10		6.5	8.1	5.3	16	
SNB2-5L						#10		6.5	9.5	5.3	16	
SNB2-6S						4-Jan		6.5	9.5	6.5	16	
SNB2-6L	16-14	1.5~2.5	4.1	2.3	4.8	4-Jan		11	12	6.5	22	27
SNB3.5-4						#8		7	8	4.3	18.3	
SNB3.5-5						#10		7	8	5.3	18.3	
SNB3.5-6	14-12	2.5~4	5	3	6	4-Jan		12.1	12	6.5	21.5	37
SNB5.5-3.5						#6		7.5	8.3	3.7	19.5	
SNB5.5-4S						#8		7.5	8.3	4.3	19.5	
SNB5.5-4L						#8		7.5	9	4.3	19.5	
SNB5.5-5						#10		7.5	9	5.3	19.5	
SNB5.5-6S						4-Jan		7.5	9	6.5	19.5	
SNB5.5-6L						4-Jan		12	12	6.5	12	
SNB5.5-8	10-Dec4~6		5.6	3.4	16.8	16-May		11.5	14	8.4	14	48